



AUDUBON WATER COMPANY

Water Quality Report January 1, 2008 to December 31, 2008

Dear Customer:

We are pleased to present a summary of the quality of the water provided to you during the past year. The Safe Drinking Water Act (SDWA) requires that utilities issue an annual "Consumer Confidence Report" to customers in addition to other notices that may be required by law. This report details where our water comes from, what it contains, and the risks our water testing and treatment are designed to prevent. AUDUBON WATER COMPANY is committed to providing you with the safest and most reliable water supply. Informed consumers are our best allies in maintaining safe drinking water.

The bottom line: Is the water safe to drink? Absolutely

Find out more about AUDUBON WATER COMPANY on the Internet at www.audubonwater.com. Our site includes this report and other information designed to educate our customers including ways you may be able to save on your usage and billing.

Overview - In 2008, Audubon Water Company continued system-wide improvement projects. This included updating well and pump stations.

Water Source - Supplied by ground water pumped from 11 wells most of which are near the Audubon section of Lower Providence Township.

Required Additional Health Information - To ensure that tap water is safe to drink, EPA prescribes limits on the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.

- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

National Primary Drinking Water Regulation Compliance

Important Information About Your Drinking Water

Este Informe Contiene Informacion Muy Importante Sobre Su Agua De Beber. Traduzcalo O Hable Con Alguien Que Lo Entienda Bien.

Monitoring Requirement Not Met for Audubon Water Company

Our water system violated a drinking water standard over the past year. Even though this was not an emergency, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2007 we missed a quarterly radiological sample at one of our wells.

What should I do?

There is nothing you need to do at this time. The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for radiologics at this well, and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were taken
Radiologics	Quarterly at one well	3	2007 3rd Quarter	2007 September 27

What happened? What was done?

The required sample was taken on September 27th as described in the last column of the table above. The sample showed we are meeting drinking water standards.

To contact AUDUBON WATER COMPANY call J.H. Russell at 610-630-1200 or visit our web site. www.audubonwater.com

Water Quality Table

<u>Detected Parameter</u>	<u>Unit</u>	<u>MCL</u>	<u>MCLG</u>	<u>Avg. Detect Level</u>	<u>RANGE</u>	<u>Major Source</u>	<u>Compliance Achieved?</u>
<u>Inorganic Contaminants</u>							
NITRATE	ppm	10	10	1.68	0.52-3.32	Erosion of Natural Deposits; Runoff from Fertilizer Use; Leaching from Septic Tanks, Sewage.	YES
<u>Organic Contaminants</u>							
ATRAZINE	ppm	0.003	0.003	0.00004	0.0002	Runoff from Herbicides used in Row Crops	YES
<u>Volatile Organic Contaminants</u>							
CARBON TETRACHLORIDE	ppm	0.005	0	0.00004	0.0-0.0008	Discharge from Industrial Chemical Factories & Metal Degreasing Sites.	YES
TETRACHLOROETHENE	ppm	0.005	0	0.00003	0.0-0.0007	Discharge from Factories & Dry Cleaners	YES
<u>Radiologics</u>							
ALPHA EMITTERS	pCi/l	15 pCi/l	0	12.5 pCi/l	12.5	Erosion of Natural Deposits	YES
COMBINED RADIUM	pCi/l	20.1 pCi/l	0	12.63 pCi/l	12.1-13.1	Erosion of Natural Deposits	YES
RADIUM 226	pCi/l	5 pCi/l	0	0.78 pCi/l	0-1.57	Erosion of Natural Deposits	YES

Audubon Water Company
P.O. Box 7337
Audubon, PA 19407

How to Read The Water Quality Table

This report is based upon tests conducted in the year 2007 by Audubon Water Company. Terms used in the Water Quality Table and in other parts of this report are defined here.

Maximum Contaminant Level or MCL: The highest level of contaminant that is allowed in drinking water MCL's are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of contaminant in the drinking water below which there is no known or expected risk to health, MCLGs allow for a margin of safety.

Regulated Contaminants:

Key

MCL = Maximum Contaminant Level

MFL = million fibers per liter

MRDLG = Maximum Residual Disinfectant Level Goal

N/A = Not Applicable

pCi/l = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter (ug/l)

ppq = Parts per quadrillion, or picograms per liter

AL = Action Level

MCLG = Maximum Contaminant Level Goal

MRDL = Maximum Residual Disinfectant Level

mrem/year = millirems per year (a measure of radiation absorbed by the body)

NTU = Nephelometric Turbidity Units (a measure of water clarity)

ppm = parts per million, or milligrams per liter (mg/l)

ppt = parts per trillion, or nanograms per liter

TT = Treatment Technique

Water Quality Table Footnotes

Although we ran many tests, only the listed substances were found. They are all below the MCL required